


SES40PSK


Service Entrance Surge Protector Sealing Kit

Step 1: Attach mounting bracket or mounting mechanism if desired.


Note: Be sure to remove lock nut first.




Step 2: Apply Blue RTV to the threads of the SES40P, then thread the 1/2" conduit coupler onto the SES40P.




Step 3: Prepare the cable gland by removing and discarding the plastic nut.




Step 4: Thread wires through cable gland and pass the gland through the conductors up to the coupler.



Step 5: Apply Blue RTV to the cable gland, loosen gland head and thread the cable gland into the coupler, taking care to not allow the cables to spin.



Step 6: Tighten cable gland and gland head using a wrench to fully seal the SES40P.



WARNING:

1. Pentair products shall be installed and used only as indicated in Pentair product instruction sheets and training materials. Instruction sheets are available at www.erico.pentair.com and from your Pentair customer service representative.
2. Pentair products must never be used for a purpose other than the purpose for which they were designed or in a manner that exceeds specified load ratings.
3. All instructions must be completely followed to ensure proper and safe installation and performance.
4. Improper installation, misuse, misapplication or other failure to completely follow Pentair's instructions and warnings may cause product malfunction, property damage, serious bodily injury and/or death, and void your warranty.

SAFETY INSTRUCTIONS:

All governing codes and regulations and those required by the job site must be observed. Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.

Pentair, CADDY, ERICO CADWELD, ERICO CRITEC, ERICO, ERIFLEX, and LENTON are owned by Pentair or its global affiliates. All other trademarks are the property of their respective owners. Pentair reserves the right to change specifications without prior notice.