

NOTICE OF COMPLETION  
AND  
AUTHORIZATION TO APPLY THE UL MARK



2017-12-06  
Revised 2018-03-23

MR. WARD JUDSON  
ERICO INTERNATIONAL CORPORATION  
34600 SOLON RD  
SOLON, OH, 44139-2631, US

Our Reference: File E316390, Vol 1

Order: 11515265  
Project: 4787671899

Your Reference: A216439

Project Scope: UL Recognition investigation of AWM Wires (AVLV2), AWM Style 11681, 11708, 11709, 11710, 11712, 11713, 11714, 11715 with Low Smoke (LS) according to IEC 61034-2, Halogen Free (HF) according to UL 2885 with evaluation to IEC 60754-1, IEC 60754-2, IEC 62821-1 Annex B and Low Smoke Zero Halogen (LSHF) Rating for FLEXIBAR ADVANCED, IBS ADVANCED, IBSB ADVANCED, IBSBR ADVANCED"; CUL Recognition Investigation of TPE insulated single, 105C and 115C dry, 60, 75, 90C wet, 1000VAC/1500VDC, Class I, Group A. File E316390.

Dear MR. WARD JUDSON:

Congratulations! UL's investigation of your product(s) has been completed under the above Reference Number and the product was determined to comply with the applicable requirements. This letter temporarily supplements the UL Follow-Up Services Procedure and serves as authorization to apply the UL Mark at authorized factories under UL's Follow-Up Service Program. To provide your manufacturer(s) with the intended authorization to use the UL Mark, you must send a copy of this notice to each manufacturing location currently authorized under File E316390, Vol 1.

Records in the Follow-Up Services Procedure covering the product are now being prepared and will be sent in the near future. Until then, this letter authorizes application of the UL Mark for 90 days from the date indicated above.

Additional requirements related to your responsibilities as the Applicant can be found in the document "Applicant responsibilities related to Early Authorizations" that can be found at the following web-site: <http://www.ul.com/EAResponsibilities>

Any information and documentation provided to you involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

We are excited you are now able to apply the UL Mark to your products and appreciate your business. Feel free to contact me or any of our Customer Service representatives if you have any questions.

Very truly yours,

Dawn Bott  
Engineering Associate  
Dawn.M.Bott@ul.com

Reviewed by:

Bruce A. Mahrenholz  
CPO Director  
Bruce.A.Mahrenholz@ul.com

47d4d49c-cf41-4c05-87ce-905480d359c0

NOTICE OF COMPLETION  
AND  
AUTHORIZATION TO APPLY THE UL MARK

