



Certificate of Compliance

Certificate: 1045431 **Master Contract:** 160371 (090005_0_000)
Project: 70173298 **Date Issued:** 2018-03-12
Issued to: **ERICO International Corporation**
34600 Solon Rd
Solon, Ohio 44139
USA
Attention: Ward Judson

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Iuliana Nita*
Iuliana Nita

PRODUCTS

CLASS - C585101 - WIRES-Appliance

Part (A): Appliance Wiring Material, Flexible Insulated Busbar (ERIFLEX FLEXIBAR), AWM, I, A/B, rated 105°C Dry / 75°C Wet, 1000V, FT1 with a PVC insulation, black colour only

Part (B): Appliance Wiring Material, Insulated Braided Conductor Flat or Round (IBS), AWM, I, A/B, rated 105°C Dry / 75°C Wet, 1000V, FT1 with a PVC insulation, black colour only

Part (C) Appliance Wiring Material, Insulated Braided Conductor for Circuit Breakers (IBSB/IBSBR), AWM, I, A/B, rated 105°C Dry / 75°C Wet, 1000V, FT1 with a PVC insulation, black colour only

Part (D): Appliance Wiring Material, Flexible Insulated Busbar (FLEXIBAR Advanced), AWM, I, A/B, rated 60C, 80C, 90C, 105°C Dry, 115°C Dry, 30V, 150V, 300V, 600V, 1000V, FT1, FT2, VW-1 with TPE insulation, all colours except clear and translucent

Part (E): Appliance Wiring Material, Insulated Braided Conductor Flat or Round (IBS Advanced), AWM, I, A/B, rated 60C, 80C, 90C, 105°C Dry, 115°C Dry, 30V, 150V, 300V, 600V, 1000V, FT1, FT2, VW-1 with TPE insulation, all colours except clear and translucent



Certificate: 1045431
Project: 70173298

Master Contract: 160371
Date Issued: March 12, 2018

Part (F): Appliance Wiring Material, Insulated Braided Conductor for Circuit Breakers (IBSB/IBSBR Advanced), AWM, I, A/B, rated 60C, 80C, 90C, 105°C Dry, 115°C Dry, 30V, 150V, 300V, 600V, 1000V, FT1, FT2, VW-1 with TPE insulation, all colours except clear and translucent

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 210 - Appliance Wiring Material Products