



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX PTB 21.0007X** Page 1 of 4 **Certificate history:**
Status: **Current** Issue No: 2 **Issue 1 (2021-04-21)**
Date of Issue: **2021-11-19** **Issue 0 (2021-03-30)**
Applicant: **nVent Thermal Belgium N.V**
Research Park Haasrode - Zone 2
Romeinse Straat 14
B-3001 Leuven
Belgium
Equipment: **Raychem HTV Range of Self-Regulating Trace Heating Systems**
Optional accessory:
Type of Protection: **Trace Heating System with Ex Components in Type of Protection increased safety 'eb', Encapsulation 'mb' and Protection by enclosure 'tb'**
Marking: **Ex eb mb 60079-30-1 IIC T6...T2 Gb**
Ex tb 60079-30-1 IIIC T85°C...T215°C Db

Approved for issue on behalf of the IECEx
Certification Body:

Dr. Ing. Detlev Markus

Position:

Head of Department "Explosion Protection in Energy Technology"

Signature:
(for printed version)

Date:

22. 11. 21

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Physikalisch-Technische Bundesanstalt (PTB)
Bundesallee 100
38116 Braunschweig
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 21.0007X**

Page 2 of 4

Date of issue: 2021-11-19

Issue No: 2

Manufacturer: **nVent Thermal Belgium N.V.**
Reasearch Park Haasrode – Zone 2
Romeinse Straat 14
Leuven 3001
Belgium

Additional manufacturing locations: **nVent Thermal LLC**
899 Broadway St.
Redwood City, CA 94063
United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-18:2017 Explosive atmospheres - Part 18: Protection by encapsulation "m"
Edition:4.1

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

IEC/IEEE 60079-30-1:2015 Explosive atmospheres - Part 30-1: Electrical resistance trace heating - General and testing requirements
Edition:1.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/PTB/ExTR21.0017/02](#)

Quality Assessment Reports:

[GB/BAS/QAR06.0030/09](#)

[GB/BAS/QAR07.0053/08](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 21.0007X**

Page 3 of 4

Date of issue: 2021-11-19

Issue No: 2

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Raychem HTV Range of Self-Regulating Trace Heating Systems consists of the aHTVb-CT self-regulating heating cable, associated junction and connection kits and special cable glands. The application covers industrial freeze protection up to temperature maintenance processes with a high maximum exposure temperature. The maximum withstand temperature of the heating cable is up to +260°C (max. continuous operating temperature is +205°C).

Any of the products in the range may be considered as part of a stabilized or controlled system design. In such systems the design is based upon nVent proprietary software such as TraceCalc, TRACERLYNX and software based on the same data and algorithms. These designs may carry temperature classes other than those described and are marked with the actual maximum temperature and the appropriate T class in parenthesis.

Nomenclature

aHTVb-CT

a: output, W/ft@10°C: 3, 5, 8, 10, 12, 15, 20

b: Voltage: 1 (120 Vac: 90~130 Vac) or 2 (240 Vac: 190~277 Vac)

Technical details

max. ambient temperature range*	-60°C to +56°C	with S-40 and E-40
	-55°C to +56°C	with JBx-100-xx and T-100 and E-100-X
	-55°C to +56°C	with C25-100, C25-21, C25-100-METAL, C25-100-METAL-NP, C25-100-METAL-SS, C3/4-100-METAL, C3/4-100-METAL-NP, C3/4-100-METAL-SS, C75-100-A
	-40°C to +40°C	with E-100-L-X and JBx-100-L-xx
max. operating temperature	+205°C	
max. withstand temperature	+260°C (Power 'on' / 'off')	
min. start up temperature	-60°C	
min. installation temperature*	-60°C	
min. bending radius	12.7 mm at -60°C	
max. rated voltage	130 Vac / 277 Vac	
max. rated circuit current	40 A	

* The temperature range for the installed assembly results from the temperature rating with the most restrictive temperature range.

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. Raychem HTV Range of Heating Cables must be installed using nVent Thermal LLC's JBM-100-E, JBM-100-A, JBM-100-EP, JBM-100-L-E, JBM-100-L-A, JBM-100-L-EP, JBS-100-E, JBS-100-A, JBS-100-EP, JBS-100-L-E, JBS-100-L-A, JBS-100-L-EP, JBU-100-E, JBU-100-A, JBU-100-EP, JBU-100-L-E, JBU-100-L-A, JBU-100-L-EP, T-100, E-100-E, E-100-A, E-100-L-E, E-100-L-A, C25-100, C25-21, C25-100-METAL, C25-100-METAL-NP, C25-100-METAL-SS, C3/4-100-METAL, C3/4-100-METAL-NP, C3/4-100-METAL-SS, C75-100-A, Connection Kits and S-40 and E-40 Integral Components.
2. Refer to the installation instructions to reduce the potential of an electrostatic charging hazard on the enclosures of the connection kits.
3. Any unconnected heating cable end must be sealed with a nVent approved end seal.
4. The end-user shall mount the equipment per nVent Thermal LLC's instructions at all times.
5. The supply to the heating unit must be terminated in a suitably certified terminal enclosure.



IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 21.0007X**

Page 4 of 4

Date of issue: **2021-11-19**

Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Including additional components (E-100-A, E-100-L-A, JBS-100-A, JBM-100-A, JBU-100-A, JBS-100-L-A, JBM-100-L-A, JBU-100-L-A, C75-100-A)